

BILAN DE PUISSANCE CAUE 14

ECLAIRAGE	PUISSANCE	SOUS-SOL	RDC	R+1	R+2	R+3	R+4	P TOTAL
TU	8		1					8
SA141	56				16			896
ET1	49	1			1			98
EV235	112	2						224
EV295	140	1						140
RF28	28		5					140
A2	2							0
SP	9,9	2						19,8
PR	36		1					36
PRV	36	5	19				8	1152
LU	42		2					84
L1	32						5	160
SA	42				2			84
HU	18		2					36
H1	52		1		1			104
AP	42		6	4	4	4	3	882
EX	24	2						48
						<u>TOTAL</u>		4111,8
						<u>avec Coef f</u>		1 4111,8

PC								
PC NORMAL	100	16	14		31		21	8200
PC ONDULE	100	4	6		20		8	3800
						TOTAL		12000
						avec Coef f	0,5	6000

ECS	2000	1	1				1	6000
AI	100		1					100
AT	100		1					100
STORE	100			3	3	3		900
CLIM	1500				1			1500
BAIE INFO	200				1			200
PLAQUES	2000						1	2000
VMC	100						1	100
ASCENSEUR	1500	1						1500
CHAUFFERIE	800		1					800
PR 1	1100	1						1100
PR 2	1100	1						1100
PR 3	1100	1						1100
PR 4	280	1						280
BAT E	4500	1						4500
C EXT	200	1						200
C SOU	150	1						150
TOTAL								21630
avec Coef f								0,8
								17304

TOTAL PUISSANCE (W) 37741,8
TOTAL PUISSANCE (W) FOISONNEE 27415,8
PUISSANCE (VA) 34269,75

INTENSITE 50A

Abonnement minimal ERDF 36KVA